

Contaminants	MCLG or MRDLG	MCL, TT, or MRDL	Detect In Your Water	Range		Sample Date	Violation	Typical Source
				Low	High			
<b>Disinfectants &amp; Disinfection By-Products</b>								
(There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants)								
Chlorine (as Cl <sub>2</sub> ) (ppm)	4	4	1.66	1.2	1.97	2018	No	Water additive used to control microbes
Haloacetic Acids (HAA5) (ppb)	NA	60	41	35	49	2018	No	By-product of drinking water chlorination
TTHMs [Total Trihalomethanes] (ppb)	NA	80	50.6	45	50.6	2018	No	By-product of drinking water disinfection
Total Organic Carbon (% Removal)	NA	TT	44	NA	NA	2018	No	Naturally present in the environment
<b>Inorganic Contaminants</b>								
Barium (ppm)	2	2	.008	NA	.022	2018	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Fluoride (ppm)	4	4	.8	.52	.98	2018	No	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
Nitrate [measured as Nitrogen] (ppm)	10	10	.98	.22	8.9	2018	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
<b>Microbiological Contaminants</b>								
Total Coliform (RTCR)	NA	TT	NA	NA	NA	2018	No	Naturally present in the environment
Turbidity (NTU)	NA		100	NA	NA	2018	No	Soil runoff
<b>Volatile Organic Contaminants</b>								
Not Detected								
Contaminants	MCLG	AL	Your Water	Sample Date	# Samples Exceeding AL	Exceeds AL	Typical Source	
<b>Inorganic Contaminants</b>								
Copper - action level at consumer taps (ppm)	1.3	1.3	.11	2018	0	No	Corrosion of household plumbing systems; Erosion of natural deposits	
<b>Inorganic Contaminants</b>								
Lead - action level at consumer taps (ppb)	0	15	1.3	2018	0	No	Corrosion of household plumbing systems; Erosion of natural deposits	